



HVAC Ingenieria S.A.



It's Hard To Stop A Trane.®



AHRI CERTIFIED®
www.ahridirectory.org

Globally Recognized. Industry Respected.

**Designed, tested
and assembled in
the USA.**

Manejadoras A4AH4

- Gabinete de acero galvanizado completamente insulado.
- Motores “Multi-speed”
- Multi-posición
- Control de Flujo instalado de Fábrica
- Certificado AHRI y UL
- All-aluminum coils
- Compatible con bombas de calor y solo frío
- Ensamblado en la fábrica **Trane** en Vidalia, Georgia; USA.





Air Handler

- Brand
A = RunTru™ Brand
- Refrigerant Type
4 = R410A
- Product Family
AH = Air Handler Unit
- Nominal Efficiency Rating
4 = 14 SEER
6 = 16 SEER
- Blower Type
P = PSC
V = Variable Speed
E = Constant Torque ECM
- Nominal Capacity
BTU/HOUR x 1000
- Major Development Sequence
Primary Design / Form Series
Alphabetic Character "A" through "Z"
- Electric Power Supply Characteristics
1 = 200-230V/1PH/60Hz or 208-230V/1PH/60Hz
- Cabinet Width Size
B = 18.5"
C = 23.5"
D = 26.5"
- Refrigerant Control
3 = TXV Non-Bleed
6 = FCCV (Flow Control/Check Valve)
- Placeholder
0 = Nothing/Blank
- Minor Development Sequence/Series
Design Change
Alphabetic Letter A through Z

A 4 A H 4 P 2 4 A 1 B 3 0 A A

A4AH4 Multi-Position Air Handler

MODEL	CAPACITY (TONS)	MOTOR TYPE	FLOW CONTROL	ELECTRIC HEAT	DIMENSIONS (IN)		
					H	W	D
A4AH4P18A1B60A	1.5	PSC	Orifice	Field Installed	45.02	18.50	21.13
A4AH4P24A1B60A	2	PSC	Orifice	Field Installed	45.02	18.50	21.13
A4AH4P30A1B60A	2.5	PSC	Orifice	Field Installed	45.02	18.50	21.13
A4AH4P36A1B30A	3	PSC	TXV	Field Installed	45.02	18.50	21.13
A4AH4P37A1C30A	3	PSC	TXV	Field Installed	51.27	23.50	21.13
A4AH4E42A1C30A	3.5	CTM	TXV	Field Installed	51.27	23.50	21.13
A4AH4E48A1C30A	4	CTM	TXV	Field Installed	51.27	23.50	21.13
A4AH4E60A1C30A	5	CTM	TXV	Field Installed	51.27	23.50	21.13